

# TRINITY RURAL WATER SUPPLY CORPORATION

P O BOX 709  
TRINITY, TEXAS 75862  
936-594-2192 FAX 936-594-8491  
trinwat@windstream.net  
trwsc.com

September 9, 2021

Our system failed to collect every required coliform sample. Although this incident was not an emergency, as our customers, you have a right to know what happened and what we did (are doing) to correct this situation. We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During September 2020 we did not monitor or test or did not complete all monitoring or testing for coliform bacteria and therefore cannot be sure of the quality of your drinking water during that time.

## WHAT SHOULD I DO?

There is nothing you need to do at this time. You may continue to drink the water. If a situation arises where the water is no longer safe to drink, we are required to notify you within 24 hours.

## WHAT IS BEING DONE?

**Samples were taken at the appropriate time however the lab we left our samples with lost them putting us in violation for the month of September 2020. As soon as we were notified the samples were lost, samples were retaken and they came back clear and we were no longer in violation.**

**For more information, please contact Trinity Rural Water Supply at 936-594-2192 or come by our office at 3841 FM 356 Trinity, TX 75862.**

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses.) You can do this by posting this notice in public place or distributing copies by hand or mail.

This notice is being sent to you by Trinity Rural Water WSC 2

Public Water System ID# TX2280028

Date Distributed: 9/20/2021

Jay Savanich, General Manager

Board Members:

Gerald Vinson, President; Alfred "Buddy" Johnson, Vice-President,  
William Fogle, Sec/Treasurer, Sidney Burton, Director, Weldon Pee, Director